

NOTICE OF DISCHARGE OF UNTREATED WASTEWATER

Moore County Public Works had a discharge of untreated wastewater near the property behind 55 Inverrary Road in Pinehurst #7 Golf Community in Pinehurst, NC on June 22, 2023, of an estimated 100 gallons. The spill was due to a damaged service line which was buried shallow underground and driven over by a contractor. The spill was reported at 10:00 a.m. and lasted for approximately one hour, while repairs to the service line and tap were made. The untreated wastewater entered an unknown tributary to Aberdeen Creek.

This notice is required by North Carolina General Statutes Article 21, Chapter 143.215C. The NCDEQ was notified of the event on June 22, 2023, at 3:15 p.m. and is reviewing the matter. For more information contact Moore County Public Works @ (910) 947-6315.